

ADDENDUM 1.0

Please see the following addendums and modified Scope Of Work to the RFP. Contractor shall review these items as clarifications to the drawings and RFP.

1. Contractor to provide 2" conduit below grade for data lines with Two (2) pull strings as indicated in the drawings for data and Owner provided fire systems trade to complete the connection to the central panel in adjacent building
2. Contractor to review the revised Foundation Pier detail S10.0 for bidding
3. This bid excludes all FF&E and it is not to be accounted for within your proposal for this RFP.
4. Contractor may provide value engineering options in reducing project cost in an "Add Alternate" bid sheet to this RFP
5. The soil reports recommend drilled piers, please disregard and bid the foundation detail on S10.0